



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From,
The Commissioner,
Greater Visakhapatnam
Municipal Corporation
Visakhapatnam.

To,
The District Educational Officer,
Visakhapatnam District,
Visakhapatnam.

Rc.No.301/RFO/FPW/GVMC/2022, Dt.10-08-2022.

SUB: Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing - Existing Building of **M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam – Fire No Objection Certificate for Occupancy** - Issued - Reg.

REF: 1. Letter Rc.No: 5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt:13/09/2019.
3. Application Dt.02-08-2022 of M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam for Fire No Objection Certificate for Occupancy.

It is to inform that, vide reference 3rd cited, an application is received by this office for issuance of Fire No Objection Certificate for Occupancy to the existing building of M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam.

2. Therefore, the Station Fire Officer, Fire Prevention wing, GVMC inspected the premises of M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam on 08-08-2022 and submitted the following report.

3. Particulars of the building:

a)	Address of the Premises	M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam
b)	Total Plot Area	4937.00 Sq. Mtrs.
c)	Height of the Building	06.00 Mtrs. 3.00 Mtrs. 10/8/22
d)	No of blocks/ floors	Ground Floor only
e)	Type of occupancy	Educational (School)

4. The floor wise details.

Sl. No.	Floor	Area in Sq. Meters.	Type of Occupancy
1	Ground	985.00	Educational (School)
	Total	985.00	

5. The builder has provided the following open spaces surrounding the building:


Side	Open spaces provided by the builder in Meters
North	06.00
South	03.00
East (Front)	06.00
West	03.00

6. Details of Means of escape provided in the Building:

- The management provided sufficient no. of doors.

7. The details of Fire Fighting Equipment required and provided by the builder.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS 2190	10 Nos.	10 Nos.	Nil
2.	Terrace Tank	5,000 Ltrs.	5,000 Ltrs.	Nil
3.	Fire Buckets	04 Nos.	04 Nos.	Nil



Contd..page.2

:: 2 ::

8. The management has remitted an amount of Rs.51,467/- vide challan No.2022-CH-06501, Dt.02-08-2022 towards fire precautionary fees and penal interest.
9. The Fire safety systems were tested by the Station Fire Officer, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Fire No Objection Certificate for Occupancy.

10. Therefore, **Fire No Objection Certificate for Occupancy** is hereby issued to the Educational Building of M/s.Adarsh Public School, Vinayak Nagar, Pedagantyada, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the fire fighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

11. The **Fire No Objection Certificate for Occupancy** issued to M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam is **valid from 10-08-2022 to 09-08-2023** and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.
12. The issuing of Fire NOC is without any prejudice to the action taken by GVMC against Unauthorized Construction, if any made.

(D.Niranjana Reddy)
Regional Fire Officer
Fire Prevention Wing,

Greater Visakhapatnam Municipal Corporation,
Visakhapatnam.

Copy to the Chief City Planner, GVMC, Visakhapatnam.

Copy to the Management, M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam.



Signed by Danda Niranjana
Reddy
Date: 10-08-2022 16:56:22
Reason: Approved

